



ABOVE GROUND TANK DESIGN

Test Certificate

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

NAME: Fuel Storage Limited
ADDRESS: 700 Bond Road
P O Box 501
Te Awamutu
Ph 0800 383 578

CERTIFICATE NUMBER: TC00747 FAB NUMBER: FAB0050
JOB NUMBER: TICL14094 TNK NUMBER: TNK14094
TANK SERIAL NUMBER: Nameplate
TANK ID: Nameplate
CAPACITY: 3,106 litres
TANK DESIGN CODE: AS 1692-2006, Cat. 3 / HSNOCOP 24-1, 3/08
MANUFACTURE YEAR: Nameplate

DRAWING NO: 1409048-01-01 SHEETS: 01 to 03 incl. REVISION: A, 2/10/14 TITLE: 3013L Double-Skin Tank General Arrangement

DATE ISSUED: 29/10/2014 EXPIRY DATE: N/A

Unless surrendered or revoked, this certificate remains valid for the service life of the tank.

Approved For:

The storage and transfer of diesel having a hazard classification of 3.1D, 6.1E, 6.3B, 6.7B, 9.1B

Subject To:

Compliance with AS 1692-2006 & HSNOCOP24-1. This Certificate becomes invalid following any change to the approved BVT Consulting design and drawings nos. 1409048-01-01 sheets 01 to 03 incl.

Graham Voss
Test Certifier Registration Number : TST000083

This certificate is issued subject to the condition that it must be able to be produced when required by an Enforcement Officer appointed under the HSNO Act 1996.

Tank Inspection and Certification Limited
152A Brooklands Road
New Plymouth 4310
New Zealand