

ABOVE GROUND TANK DESIGN

Test Certificate

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

NAME: Fuel Storage Limited
ADDRESS: 700 Bond Road
P O Box 108
Te Awamutu
Ph 0800 623 255

CERTIFICATE NUMBER: TC01572
JOB NUMBER: J12142
TANK SERIAL NUMBER: Name Plate
CAPACITY: 43,500 litres
TANK DESIGN CODE: AS 1692-2006, Category 3
MANUFACTURE YEAR: Name Plate
TNK NUMBER: TNK15026

DRAWING NO: 1508694-01
SHEETS: 1 to 3 incl.
REVISION: A, 18-09-15
TITLE: 40,000 Litre Tank General Assembly

DATE ISSUED: 01/11/2017
EXPIRY DATE: N/A

Unless surrendered or revoked, this certificate remains valid for the service life of the tank.

Approved For:

The storage and transfer of diesel only having a hazard classification of 3.1D, 6.1E, 6.3B, 6.7B, 9.1B

Subject To:

Compliance with AS 1692-2006. This Certificate becomes invalid following any change to the approved BVT Consulting Drawing No. 1508694-01, Sheets 1 to 3 incl, dated 18-09-15.



Graham Voss
Test Certifier Registration Number : TST000083

This certificate is issued subject to the condition that it must be able to be produced when required by an Enforcement Officer appointed under the HSNO Act 1996.

Stork Technical Services New Zealand Limited
107-109 De Havilland Drive
New Plymouth 4312
New Zealand