

ABOVE GROUND TANK DESIGN

Test Certificate

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

NAME: Fuel Storage Limited

ADDRESS: 700 Bond Road

P O Box 108 Te Awamutu Ph 0800 623 255

CERTIFICATE NUMBER: TC01586 TNK NUMBER: TNK16023

JOB NUMBER: J12142

TANK SERIAL NUMBER: Name Plate

CAPACITY: 31,755 Litres

TANK DESIGN CODE: AS 1692 - 2006, Category 3

MANUFACTURE YEAR: Name Plate

DRAWING NO: SHEETS: REVISION: TITLE:

16101577-01 & 02 3 of 3 & 2 of 2 A, 19-10-16 30,000 Litre Rectangular Tank

DATE ISSUED: 21/11/2017 EXPIRY DATE: N/A

Unless surrendered or revoked, this certificate remains valid for the service life of the tank.

Approved For:

The storage and transfer of diesel only having a hazard classification of 3.1D, 6.1E, 6.3B, 6.7B, 9.1B. Approved to supply a burner or engine.

Subject To:

Compliance with AS 1692-2006. This Certificate becomes invalid following any change to the approved referenced BVT Consulting Drawings.

Graham Voss

Test Certifier Registration Number: TST000083

This certificate is issued subject to the condition that it must be able to be produced when required by an Enforcement Officer appointed under the HSNO Act 1996.

New Zealand

New Plymouth 4312

107-109 De Havilland Drive

Stork Technical Services New Zealand Limited