

ABOVE GROUND TANK DESIGN
Test Certificate

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

NAME: Fuel Storage Limited
ADDRESS: 700 Bond Road
P O Box 108
Te Awamutu
Ph 0800 623 255

CERTIFICATE NUMBER: TC01205
JOB NUMBER: TICTL16009
TANK SERIAL NUMBER: Name Plate
CAPACITY: 4,788 Litres
TANK DESIGN CODE: AS 1692 - 2006, Category 3
MANUFACTURE YEAR: Name Plate

TNK NUMBER: TNK16003

DRAWING NO: 1301001-02-01
SHEETS: 1 to 5 incl.
REVISION: A, 26-03-13
TITLE: 4,800 Litre Tank - General Assembly Drawing

DATE ISSUED: 15/10/2016
EXPIRY DATE: N/A

Unless surrendered or revoked, this certificate remains valid for the service life of the tank.

Approved For:

The storage and transfer of diesel only having a hazard classification of 3.1D, 6.1E, 6.3B, 6.7B, 9.1B supplying a burner or engine.

Subject To:

This certificate becomes invalid following any change to the original BVT Consulting design file reference 1301001 drawings and or design parameters.



Graham Voss
Test Certifier Registration Number : TST000083

This certificate is issued subject to the condition that it must be able to be produced when required by an Enforcement Officer appointed under the HSNO Act 1996.

Stork Technical Services New Zealand Limited
107-109 De Havilland Drive
New Plymouth 4312
New Zealand