

MIN 400 BETWEEN TANK AND BOLLARD

BOLLARDS - MAX 1500MM BETWEEN

POWER CONDUIT LOCATION

SEISMIC & UPLIFT RESTRAINTS

CONCRETE PAD
AS PER FOUNDATION REPORT

2832

3306

1551

1790

1310

NOTES / AMENDMENTS:



DRAWING NO: FSL 1800 DS ON GROUND TANK

SCALE: 1:30 SHEET NO: 1

DIMENSIONS: MM ISSUE DATE: 3/08/2021

DRAWN BY: BAZ A4