

COMPLIANCE CERTIFICATE

Stationary Container Tank or Process Container Design

Issued in accordance with regulations 6.23 and 17.93(1)(a) of the Health and Safety at Work (Hazardous Substances) Regulations 2017

This certificate certifies that the requirements prescribed in regulation 17.93(1)(a) for a stationary container tank or process container design compliance certificate have been met

Unique Register Number:	CER-0241-089265	CC Certificate Number:	100241-6644-09
Company / Legal Entity:	FUEL STORAGE LIMITED		
Postal Address:	PO Box 108, Te Awamutu, 3840		
Physical Address:	700 Bond Road, Te Awamutu, 3800	Companies Office No.:	+64 7 870 2927
NZBN:	9429038039096		
Full Name:	Regan McFall	Email Address:	regan@fuelstorage.co.nz
Primary Phone Number:	+64 27 948 1930		

Tank / Container Details:

Description:	20,000 Litres above ground double skinned rectangular stationary tank	Design Specification:	AS1692: 2006
Tank Type:	Above Ground Stationary Tank	Drawing Numbers:	FSL-DS20000-01-01, Rev 3, Sheets: 1 to 5, Drawn: Baz, Title: Tank Size 20,000L, Date: 11/07/2022
Name of Designer:	Fuel Storage Limited - Baz Burt	Capacity:	19,707 Litres
Compartments:	1		

Substances

Name:	Class(es):
Diesel	3.1D, 6.7B

Details of Certification:

Project Number: 6644
TNK No.: TNK20173
FAB No.: FAB0050
Tank Design Code: AS 1692:2006, Category 3
Date of Manufacture: Name Plate
Manufacturer's Tank Serial No.: Name Plate
Maximum Safe Fill Level = 18,639 Litres

Approved For:

The storage and transfer of Diesel only, having a hazard classification of 3.1D, 6.1E, 6.3B, 6.7B, 9.1B.

References:

Compliant with AS 1692:2006, Category 3.

6643-1005, 20kL Tank Design Statement, Rev 00 Released, 02Aug22: – In accordance with AS 1692:2006, Load combinations: AS/NZS 1170.0:2002, Wind loading: AS/NZS 1170.2:2011 & Seismic loading: NZS 1170.5:2004, seismic loading to NZSEE method, Joe Bain (CPEng 248672), Dated 2/8/22. Allocation of unique serial number for each tank and retention of individual tank fabrication and testing records.

The TNK register number is to be marked on the tank nameplate in addition to the manufacturers serial number, date of manufacture, pressure test in kPa and safe fill level. All other markings to comply with the Hazardous Substances Regulations.

QA inspection and documentation to be completed before installation of the tank/s.

Re-certification required following any change to the referenced contents, original design, duty, service conditions, referenced Fuel Storage Limited drawings or applicable standards.

Issued Date:
04 August 2022

Date Comes Into Force:
04 August 2022

Expiry Date:
04 August 2032



Callum Eli Gates
Worksafe Authorised Compliance Certifier (TST100241)

This certificate is issued by Callum Eli Gates, being an individual compliance certifier authorised by WorkSafe New Zealand under regulation 6.8 of the Health and Safety at Work (Hazardous Substances) Regulations 2017, in accordance with regulation 6.8(2)(a) to (d) of those regulations.

Motovated Design & Analysis Ltd
PO Box 9114
Christchurch 8024
Phone: +64 3 982 5283
www.motovated.co.nz

MOTOVATED
Engineering Your Vision