

ABOVE GROUND TANK DESIGN

Compliance Certificate

Issued in accordance with regulations 6.23 and 17.93(1)(a) of the Health and Safety at Work (Hazardous Substances) Regulations 2017. This certificate certifies that the requirements prescribed in regulations 17.93(1)(a) for a stationary container tank or process container design compliance certificate have been met.

NAME: Fuel Storage Limited
ADDRESS: 700 Bond Road
P O Box 108
Te Awamutu
Ph 0800 623 255

CERTIFICATE NUMBER:	CC02261	FAB NUMBER:	FAB0050
JOB NUMBER:	J31984	TNK NUMBER:	TNK20038
TANK SERIAL NUMBER:	Name Plate		
TANK ID:	Name Plate		
CAPACITY:	4,950 Litres		
TANK DESIGN CODE:	AS 1692-2006, Cat 3.		
MANUFACTURE YEAR:	Name Plate		

DRAWING NO:	SHEETS:	REVISION:	TITLE:
1301001-01	1 to 4 incl.	0, 09-20	Tank Size 4800 DS Tank
DATE ISSUED:	04/12/2020	COMMENCEMENT DATE:	04/12/2020
		EXPIRY DATE:	04/12/2030

Approved For:

The storage and transfer of diesel only having a hazard classification of 3.1D, 6.1E, 6.3B, 6.7B, 9.1B. Approved to supply a burner or engine.

References:

Maximum safe fill level = 4,800 litres.

Compliance with AS 1692-2006.

Refer LogiCamms statement of design compliance Certificate No. 11-01038.01-06-RPT-001 Rev 0.

Allocate unique serial number for each tank and retain fabrication records.

Recertification required following any change to the approved referenced Drawings and / or original design parameters.



Graham Voss

Compliance Certifier Registration Number: TST000083

Stork Technical Services New Zealand Limited
107-109 De Havilland Drive
New Plymouth 4312
New Zealand